

---

## CORROSION COUPON SAMPLING PROCEDURE

1. Remove the Corrosion Classification Coupon (CCC) from the plastic packing bag. Keep this bag for use when returning the coupon to Purafil.
2. Fill in all the information fields on the label affixed to the CCC.

Required Information:

- Company Name
- Address
- Room/Area Identification
- Date Installed (The date you initially expose the CCC. Fill in “Date Out” when coupon is removed)

**IMPORTANT: A report cannot be provided for any coupon missing any of the required information.**

3. Place the coupon in selected area for the predetermined period. (Typically 30 days, though it can be left for up to 90 days in very mild environments. Coupons in harsh environments may become highly tarnished in 30 days)
4. Conduct regular visual inspections in harsh environments. If the coupon is visibly corroded, it can be returned early for faster results. Accurate date-in and date out information is critical for accurate results.
5. After the predetermined time expires, remove the coupon from the selected area.
6. Enter the date of removal on label affixed to CCC.
7. Place the CCC in the plastic bag. Return to Purafil Laboratory at the below address:  
**Purafil – Chelsea Newton-Lab**  
**2654 Weaver Way**  
**Doraville, Georgia 30340**
8. An Air Quality Analysis Report will be sent to your Purafil Sales Representative within 2 weeks of being received by the Purafil Lab.

**NOTE: Keep a copy of the CCC Panel number for your record**